



E-mail MEMO:
Please Copy and Distribute
WX-2022-7

MEMO

TO: Agency Directors and Weatherization Coordinators
FROM: Michael Figueredo, Weatherization T&TA Coordinator
RE: Updated Performance Ratings for Heating and Cooling Systems
DATE: December 20, 2022

Greetings,

In light of new industry standards for testing the performance of split heating and cooling systems from AHRI, this memo is directed to clarify and revise the previous Memo (WX-2022-3) and update the standards to accommodate and minimize impact in the WAP for BPA-eligible projects.

Effective January 1st, 2023, installing new electric split systems must meet one of the following standards for both heating and cooling efficiencies to be eligible in the program:

HSPF: 9.0
SEER: 14.0

OR

HSPF2: 7.6
SEER2: 13.4

If you have any questions, please contact me at (503) 986-0972.

Best regards,

Michael Figueredo
Weatherization T&TA Coordinator